

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 7:46:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEP-CBXRFK Lab Sample ID: H2063337

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 9:57:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEP-CBXRFE Lab Sample ID: H2063330

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 8:55:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: , Storage tank #1
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEP-CBXRFH Lab Sample ID: H2063333

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 8:55:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEP-CBXRFJ Lab Sample ID: H2063336

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 8:45:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEP-CBXRFGLab Sample ID: H2063331

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 9:06:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEF-CBXRFD Lab Sample ID: H2063329

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 9:17:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEP-CBXRFC Lab Sample ID: H2063324

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 4/27/2022 7:31:00 AM
Date: April 30, 2022 at 1:57 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 04/27/2022

Operator: Janine Reimer
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEP-CBXRFF Lab Sample ID: H2063332

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310