

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 10:07:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEF-D4NPN7 Lab Sample ID: H3601004

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 10:15:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEF-D4NPN2 Lab Sample ID: H3600993

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 9:02:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage tank #1
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEF-D4NPN5 Lab Sample ID: H3601005

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 9:10:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEF-D4NPN6 Lab Sample ID: H3601009

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 8:49:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEF-D4NPN4 Lab Sample ID: H3601012

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 9:25:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEF-D4NPMZ Lab Sample ID: H3600998

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 9:37:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEF-D4NPMY Lab Sample ID: H3600994

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 7/23/2024 9:51:00 AM
Date: July 26, 2024 at 2:01 AM
To: administrator@savaryshoreswater.ca, floracopley26@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 07/23/2024

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEF-D4NPN3 Lab Sample ID: H3600995

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310