

From: HS Agent HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018
Date: March 23, 2018 at 6:12 AM
To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: TCLE-AVGRN4 Lab Sample ID: B8WT000378

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:12 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: TCLE-AVGRMF Lab Sample ID: B8WT000377

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:12 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, courtney.robertson808@gmail.com, administrator@savaryshoreswater.ca



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: , Storage tank #1
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: TCLE-AVGRMU Lab Sample ID: B8WT000373

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:11 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District

Sample Location: Savary Shores, Storage Tank #2

Date Collected: 03/20/2018

Operator: Savary Shores Improvement District

(Blank)

(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC

Sample ID: TCLE-AVGRMY Lab Sample ID: B8WT000360

WATER TEST RESULTS:

Total Coliform per 100 mL: T

Comments:

T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS COMPLETED. NO WRITTEN REPORT WILL BE ISSUED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:11 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: TCLE-AVGRMM Lab Sample ID: B8WT000371

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:11 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



**DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH**

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: TCLE-AVGRMC Lab Sample ID: B8WT000362

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:11 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com

HA

DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: TCLE-AWD2L5 Lab Sample ID: B8WT000364

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310

From: HS Agent HAgent@healthspace.com

Subject: Drinking Water Report for Savary Shores Improvement District - 3/20/2018

Date: March 23, 2018 at 6:11 AM

To: bs_taylor@shaw.ca, dan.glover@vch.ca, administrator@savaryshoreswater.ca, courtney.robertson808@gmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 03/20/2018

Operator: Savary Shores Improvement District
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: TCLE-AVGRMK Lab Sample ID: B8WT000353

WATER TEST RESULTS:
Total Coliform per 100 mL: T

Comments:
T:SAMPLE SUBMITTED UNSATISFACTORY.EXCEEDED 30 HOURS HOLDING TIME.PLEASE
RESAMPLE. QUALITATIVE RESULT WILL BE REPORTED BY TELEPHONE WHEN TEST IS
COMPLETED.

FOR FURTHER INFORMATION PLEASE CALL: Dan Glover (604) 485-3310