

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 9:55:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Wellhead #1  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC  
Sample ID: AWEF-DC4TK2 Lab Sample ID: H4177596

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 10:02:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, NEW Wellhead #2  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC  
Sample ID: AWEF-DC4TJV Lab Sample ID: H4177589

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 9:22:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Storage tank #1  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC  
Sample ID: AWEF-DC4TJY Lab Sample ID: H4177584

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 9:27:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Storage Tank #2  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC  
Sample ID: AWEF-DC4TJZ Lab Sample ID: H4177587

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 9:39:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #1  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC  
Sample ID: AWEF-DC4TJX Lab Sample ID: H4177570

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 9:09:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #2  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC  
Sample ID: AWEF-DC4TJU Lab Sample ID: H4177574

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 8:58:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #3  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC  
Sample ID: AWEF-DC4TJT Lab Sample ID: H4177586

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

**From:** HS Agent HAgent@healthspace.com  
**Subject:** Drinking Water Report for Savary Shores Improvement District - 3/18/2025 8:45:00 AM  
**Date:** March 21, 2025 at 2:00 AM  
**To:** administrator@savaryshoreswater.ca, floracopley26@gmail.com

---



DRINKING WATER REPORT  
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District  
Sample Location: Savary Shores, Sample Station #4  
Date Collected: 03/18/2025

Operator: Kerby Fisher  
(Blank)  
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC  
Sample ID: AWEF-DC4TJW Lab Sample ID: H4177590

WATER TEST RESULTS:  
Total Coliform per 100 mL: LT1  
E. Coli per 100 mL: LT1

Comments:  
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310