

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 9:30:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Wellhead #1
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYH Lab: BCCDC
Sample ID: AWEF-CCSUX9 Lab Sample ID: W2095287

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 9:43:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, NEW Wellhead #2
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: TCLE-8VERCB Lab: BCCDC
Sample ID: AWEF-CCSUX4 Lab Sample ID: W2095280

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 10:03:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: , Storage tank #1
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-83ZMH9 Lab: BCCDC
Sample ID: AWEF-CCSUX7 Lab Sample ID: W2095285

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 10:03:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Storage Tank #2
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYM Lab: BCCDC
Sample ID: AWEF-CCSUX8 Lab Sample ID: W2095288

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 9:55:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #1
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFAYL Lab: BCCDC
Sample ID: AWEF-CCSUX6 Lab Sample ID: W2095284

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 10:14:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #2
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: DGLR-7TWTFM Lab: BCCDC
Sample ID: AWEF-CCSUX3 Lab Sample ID: W2095281

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 10:25:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #3
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: MVVE-4WFB2F Lab: BCCDC
Sample ID: AWEF-CCSUX2 Lab Sample ID: W2095279

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310

From: HAgent@healthspace.com
Subject: Drinking Water Report for Savary Shores Improvement District - 5/24/2022 10:36:00 AM
Date: May 27, 2022 at 2:00 AM
To: administrator@savaryshoreswater.ca, emerdubois@gmail.com, jakebanting@hotmail.com



DRINKING WATER REPORT
VANCOUVER COASTAL HEALTH

Facility Name: Savary Shores Improvement District
Sample Location: Savary Shores, Sample Station #4
Date Collected: 05/24/2022

Operator: Kerby Fisher
(Blank)
(Blank), (Blank) (Blank)

Site ID: BFOH-68SPPJ Lab: BCCDC
Sample ID: AWEP-CCSUX5 Lab Sample ID: W2095283

WATER TEST RESULTS:
Total Coliform per 100 mL: LT1
E. Coli per 100 mL: LT1

Comments:
LT1: Less than 1

FOR FURTHER INFORMATION PLEASE CALL: Jack Davidson (604) 485-3310